

SELECTIVE MICRO®

Chlorine Dioxide Test Strips

Product Data Sheet

Description: Selective Micro® Test Strips are made specifically for Selective Micro Technologies to measure the concentration of Selective Micro chlorine dioxide solutions.

Overview: Selective Micro Test Strips are used for quick and easy verification of chlorine dioxide solution concentration and flush out. Dipping the test strip in water produces a color change on the active test pad of the test strip. The color correlates to the concentration of chlorine dioxide in the water. A color comparator panel on the container is used to determine the chlorine dioxide concentration from 0 to 500 ppm.



Product Usage

Instructions: Use the Wide Range (0-500ppm) test strips to measure or verify use concentrations up to 500ppm. Use the Low Range (0-10ppm) to more accurately measure low concentrations. The low range test strips are recommended for verification of flush out of chlorine dioxide. Directions: Immerse strip in solution for 2 seconds. Remove strip with pads face up. Do not shake off excess water. Compare to color chart immediately. Discard strip after 15 seconds.

Dimensions: Length = 0.19 inches (0.5 cm)
Width = 2.7 inches (7 cm)

Shelf Life / Storage:

The unopened bottle has a typical shelf life of 1 year. Use prior to the expiration date stamped on the bottle. Store closed in a cool dry place below 50°C (122°F). Keep product out of direct sunlight.

Packaging: The test strips are packaged 50 per re-closable plastic bottle. A lot number and expiration date is printed on each bottle.

Ordering

| Ordering Information: | <u>Description</u> | <u>Catalog Number</u> | <u>Quantity</u> |
|-----------------------|------------------------------------|-----------------------|-----------------|
| | Low Range Test Strips (0-10 ppm) | TP001 | 50/bottle |
| | Wide Range Test Strips (0-500 ppm) | TP002 | 50/bottle |

Selective Micro Technologies believes the information contained on this data sheet is accurate. The suggested procedures are based on experience as of the date of publication. They are not necessarily all-inclusive nor fully adequate in every circumstance. Also, the suggestions should not be confused with nor followed in violation of applicable laws, regulations, or rules of insurance requirements.

Selective Micro and logo are registered trademarks and Selective Micro is a trademark of Selective Micro Technologies, LLC.

NO WARRANTY IS MADE, EXPRESS OR IMPLIED, OF MERCHANTABILITY, FITNESS FOR A PARTICULAR PURPOSE OR OTHERWISE.